

**TEST REPORT**

Water sample collected from drinking point supply through DJB in premises of Queen Mary's School, sector - 25, Rohini, Delhi vide challan no. 324 dated 28.03.2019.

S. No.	PARAMETERS	UNITS	S1
1	Date of collection	--	01.04.2019
2	Date of Analysis	--	03.04.2019
3	Colour	Hazen	Clear
4	Odour	--	No Obj.
5	Turbidity	N.T.U	1.01
6	p <sup>H</sup> value	--	7.5
7	Electrical Conductivity	µmhos/cm	266.0
8	Total Dissolved Solid	(mg/l)	172.9
<b>CHEMICAL EXAMINATION</b>			
9	Phenolphthalein Alkalinity	(mg/l)	Nil
10	Total Alkalinity	(mg/l)	78.0
11	Total Hardness	(mg/l)	124.0
12	Calcium Hardness	(mg/l)	92.0
13	Magnesium Hardness	(mg/l)	32.0
14	Calcium as Ca	(mg/l)	36.8
15	Magnesium as mg	(mg/l)	7.68
16	Ammonia (free & saline)	(mg/l)	NIL
17	Nitrite -Nitrogen (N)	(mg/l)	NIL
18	Nitrate (NO <sub>3</sub> )	(mg/l)	3.58
19	Sulphate (SO <sub>4</sub> )	(mg/l)	16.13
20	Chloride (Cl)	(mg/l)	14.0
21	Iron (Fe)	(mg/l)	0.02
22	Fluorides (F)	(mg/l)	0.24
23	Cyanides (CN)	(mg/l)	Abst.
24	Residual Chlorine	(mg/l)	0.50
<b>BACTERIOLOGICAL EXAMINATION</b>			
25	Coliform per 100 ml at 37°C	MPN/100 mL	0



NOTE: On the basis of tested parameters, water sample (S1) confirm to drinking water specification I.S 10500:2012, therefore it may be used for drinking purpose.

*[Signature]*  
3/4  
Assft. Chemist


*[Signature]*  
5/4/19  
Chemist/Bacteriologist

*[Signature]*  
A.C.W.A. (HP I)

*[Signature]*  
Manager  
Queen's Convent School  
(Formerly Queen Mary's School)  
Sector-25, Rohini, Delhi-110085

*[Signature]*  
Principal  
Queen's Convent School  
(Formerly Queen Mary's School)  
Sector-25, Rohini, Delhi-110085

दिल्ली नगर निगम



NORTH DELHI MUNICIPAL CORPORATION  
NARELA ZONE, NARELA, DELHI-110040

**SCHOOL HEALTH CERTIFICATE**

D No DHO/NRZ/2020/370

DATE:- 09/09/2020

DATE OF INSPECTION : 08/09/2020

1. NAME OF SCHOOL : **QUEEN'S CONVENT SCHOOL**
2. ADDRESS : SECTOR-25, ROHINI, DELHI-110085
3. NO. OF SHIFTS : ONE TIMING: 08:00 AM TO 02:30 PM

ACCOMODATION PROVIDED:-

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.

THE CLASSES ARE WELL LIGHTED.

THE CLASSROOMS ARE WELL VENTILATED.

THE CLASSROOMS ARE KEPT NEAT AND CLEAN.


THE DRINKING WATER IS WATER TEST REPORT APPROVED BY DJB Lab..

THE TOILET ARRANGEMENT IS SANITARY &HYGIENIC AND SUFFICIENT IN NUMBER.

REMARKS: THIS CERTIFICATE DOES NOT INDICATE'S PERMISSIBILITY FROM LAND POINT OF VIEW.


The certificate is valid for a period of one year from the date of issue.

The PRINCIPAL

  
Principal  
Queen's Convent School  
(Formerly Queen Mary's School)  
Sector-25, Rohini, Delhi-110085



  
Principal  
Queen's Convent School  
(Formerly Queen Mary's School)  
Sector-25, Rohini, Delhi-110085

  
DY.HEALTH OFFICER  
NARELA ZONE